



# Test Report

---

Report No.	WP-19057491-JC-01 En
Sample Name	Drain Channel Cover
Sample Origin	Entrusted Inspection
Client	Hangzhou Moonbay Industrial Co., Ltd.

Microspectrum Technology Co., Ltd.

# Test Report

Report No.: WP-19057491-JC-01 En

Page No.: 1 / 5

Name of Sample	Drain Channel Cover		
Number	/	Specification	/
Description of Sample	Solid	Lot No./Type	/
Client	Hangzhou Moonbay Industrial Co., Ltd		
Client Address	703 Building 2, Zhongdong International Plaza, Fengqing Avenue, Xiaoshan, Hangzhou, China		
Sampling Date	/	Sample Receiving Date	2019-06-06
Test Date	2019-06-06~2019-06-17		
Test Item(s), Criterion(s) and Result(s)	Please see the next page(s)		
Note(s)	/		

Compiled by:

*Wen Liang*

Inspected by:

*Lily*

Approved by:

*Lily*

Issued Date:

2019-06-17

# Test Report

Report No.: WP-19057491-JC-01 En

Page No.: 2 / 5

## 1. Test Result(s):

Sample No.	Sample Name	Test Item	Test Result	Unit	Test Criterion
19060546-1	Drain Channel Cover	Bearing test	29130 N (2972kgf)	/	Internal laboratory method

### Note(s):

1. Test speed:5mm/min.

\*\*\* End of the Page \*\*\*

# Test Report

Report No.: WP-19057491-JC-01 En

Page No.: 3 / 5

## 2. Typical Attachment(s):




Fig.1 Test pressure curve picture of sample load-bearing test



Fig.2 Pictures of sample before load-bearing test

\*\*\* End of the Page \*\*\*

# Test Report

Report No.: WP-19057491-JC-01 En

Page No.: 4 / 5




Fig.3 Pictures of sample during load-bearing test



Fig. 4 Pictures of sample after load-bearing test

\*\*\* End of the Page \*\*\*

# Test Report

Report No.: WP-19057491-JC-01 En

Page No.: 5 / 5

### 3. Sample Picture(s):



\*\*\* End of the Report \*\*\*

### DECLARE:

1. The report is invalid without the stamp of special seal for report or without the signature of the compiler, the inspector and the approver.
2. No unauthorized changes, additions or deletions shall be made to the report.
3. Neither fragmented report nor its incomplete copy shall be deemed valid. The complete copy is invalid without the stamp of special seal for report.
4. Any queries on the report shall be presented to Microspectrum Technology Co., Ltd. within 15 working days after receipt of the report.
5. The results described here in this report are based on the sample(s) tested. The results are presented to the client for internal uses only and do not constitute any social grounds in the People's Republic of China.
6. The client takes full responsible for the truthfulness of the testing sample(s) and information related thereto.