

Test Report

Report Number:140719001SHJ-BP-3

Applicant Name: Hangzhou Moonbay Industrial Co.,Ltd. Original Report Date: July 19, 2014
Applicant Address: 12th floor Ning'an mansion,
North Shixin Road, Xiaoshan District,
Hangzhou, China
Attn: Chris

Sample Description:

Product: Adjustable Pedestal
Model: MB-S
Samples Quantity: 3 sets
Sample ID: S140719001SHJ-001~003
Date Received: July 16, 2014
Date Test Conducted: July 17, 2014~July 19, 2014

Tests Conducted:

Test Methods: CISCA 2007

Conclusion:


For details refer to attached page(s).
The conclusions of this test report may not be used as part of the requirements for Intertek product certification.
Authority to Mark must be issued for a product to become certified.

Should you have any queries about the test report, please contact:


Approved by:

Checked by:

Prepared by:



Sun Sun
Operation Supervisor



Daniel Zhang
Senior Project Engineer



Evelyn Cui
Assistant Engineer

Test Report

Report Number: 140719001SHJ-BP-3

Test Items, Method and Results:

Character	Result	
Pedestal Axial Load Test	Claimed finished Floor Height: 400 mm	
	Pedestal Assembly 1	18.6 kN
	Pedestal Assembly 2	18.9 kN
	Pedestal Assembly 3	16.6 kN
	Average	18.4 kN

Appendix A: Sample photos




Fig.1 Received sample




Fig.2 Drawing of the sample

The End of Report

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.